



## Latex Manufacturer

The wastewater sample when received was a pH of 10.3 and according to the request for a solution to remove TSS and obtain better water clarity we began using various Floccin™ blends until the water clarity was acceptable. We had better results combining the two types of wastewater and performing the jar test.

The treatment we recommend is to use Floccin™ 1119 first at 4 lbs. per 1,000 gallons and add a small amount of base to lower the pH to 7.5. The jar test results are shown below and indicate the untreated solids on the right and the treated with the 1119 separated very well, you can see the slight difference in the bottom of the treated jar. The Floccin™ 1119 is shipped in 50 lb. bags and is priced very reasonably at \$1.25/ lb. at 2,000 pallet quantities. Trial sizes of the Floccin™ 1119 are available.

