

Anodizing Treatability



Integrated Engineers, Inc. conducted a treatability test that showed the Floccin-K worked extremely well at a dosage of 3 grams/1,000 ml of wastewater (treatment dosage of 25 lbs. of Floccin-K to 1,000 gallons of wastewater) with the addition of 0.5 ml of 20% diluted caustic. The treated pH was 7.0. The floc formed was good and the water clarity is excellent.