



Integrated Engineers, Inc. conducted a treatability test that showed the Floccin K worked extremely well at a dosage of 3 grams/1,000 ml of wastewater (treatment dosage of 25 lbs. of Floccin-K to 1,000 gallons of wastewater). The treated pH was 7.0. The floc formed and clarity of the treated water was excellent.